



CITY OF PALM BEACH GARDENS

PURCHASING DEPARTMENT

SOLICITATION ADDENDUM

Addendum No. 10

DATE: May 23, 2023

TO: All Potential Bidders

SOLICITATION NO.: ITB2023-159CS

TITLE: Burns Road Community Center Modernization & Expansion Project  
– Construction Services

DUE DATE: Friday, May 26, 2023 @ 3:30PM

This Addendum is and does become a part of the above-mentioned solicitation.

The following questions were received from potential a bidder and the responses are provided as shown below.

Question 1: Schedule on A2-702 indicates stain ST-04. Please provide location of this staining or indicate it is not applicable to the project.  
Response: *ST-04 is located on 13/A2-500 and 22/A1-213 (Children's sink frame for tile in all rooms and infants wall).*

Question 2: Drawing A2-702 indicates WC-03 at Day Care front desk. This wallpaper is not found on drawings. Please confirm this wallpaper is not applicable to the project.  
Response: *WC-03 is located on 5&6/A2-210 and 1/A2-107 (front desk soffit front, sides, and bottom. Front desk back wall @office door).*

Question 3: Please provide specifications for wall type X9 shown on sheet ALT-1.  
Response: *X9 is Stucco system over fluid applied water proofing membrane over existing CMU wall.*

All other terms, covenants and conditions of the subject solicitation and any addenda issued thereto shall apply, except to the extent herein amended.

*Km! Ra*

CPPO, CPPB, CPSM, C.P.M., CAP-OM, CPCP, FCCM, PMP  
Purchasing and Contracts Director